



MANUFACTURING

CON-SERV MFG Reverse Osmosis Operation and Maintenance Log

DATE	PRODUCT GPM	REJECT GPM	PUMP DISCHARGE PRESSURE	FEED TDS PPM	PRODUCT TDS PPM	FEED WATER TEMP	FEED WATER HARDNESS	FEED WATER CHLORINE LEVEL	PRE FILTER INLET PRESSURE	PRE FILTER OUTLET PRESSURE	REMARKS

Note: Change the prefilter when the differential pressure increases 5 –10% over the clean differential pressure
Clean the membrane(s) when the product flow rate drops by 15% or more

